



George S. Latimer  
County Executive

Department of Environmental Facilities

Vincent F. Kopicki, P.E.  
Commissioner

March 20, 2024

Sleepy Hollow Local Development Corporation  
28 Beekman Avenue  
Sleepy Hollow, NY 10591

Attn: Mr. Daniel Briar,

**RE: Ground Water Remediation**

Permit # 508-24  
Site: East Parcel  
Section 115.11, Block 1, Lots 2 & 85  
Sleepy Hollow, NY 10591

The wastewater discharge from the above-mentioned site may be discharged to the County Sewer System. The permit holder shall comply with all conditions as outlined in County Sewer Act, Chapter 824 of Laws of Westchester County. The limitations and requirements are as follows:

- 1) Effective dates of permit – **03/20/2024 to 09/19/2024** inclusive.
- 2) Maximum discharge to the sewer in Gallons per Day is **15 gpm** – based on monthly average. Flow shall be recorded each week using non-resettable flow meter.
- 3) Treatment – Sewer Use Ordinance (SUO) limitations (enclosed).
- 4) Analyses of treated wastewater for all limitations stated in SUO sent to this office within 30 days of permit date.
- 5) Additional set of analyses every **60 days** if site is active for longer than 30 days.
- 6) Notification, in writing, to this office when site is no longer active for 30 days and/or remediation work is complete.

If you have any further questions or concerns, please contact our office at (914)813-5431 or by e-mail [mew3@westchestercountyny.gov](mailto:mew3@westchestercountyny.gov)

Monika Wieleba  
Industrial Pretreatment Program



George S. Latimer  
County Executive

Department of Environmental Facilities

Vincent F. Kopicki, P.E.  
Commissioner

### LOCAL SEWER LIMITATIONS

<b><u>REGULATED POLLUTANT</u></b>	<b><u>AVERAGE DAILY CONCENTRATION</u></b> (mg/L)
pH – Low	5.5
pH – High	9.5
Arsenic	0.2
Barium	2.0
Cadmium	0.7
Chromium (Total)	3.0
Chromium (Hex)	2.0
Copper	2.8
Cyanide (Total)	0.8
Lead	0.4
Mercury	0.2
Nickel	2.8
Oil & Grease	100.0
Phenols	4.0
Selenium	0.2
Silver	0.8
Total Toxic Organics	2.1
Zinc	1.8